



Dallas County Community College District  
Purchasing Department  
4343 IH-30  
Mesquite, Texas 75150

September 20, 2019

ADDENDUM NO. 5

RFBC No. 2019-8  
Family Restroom Renovations, Gender Neutral Project at Eastfield College  
3737 Motley Drive  
Mesquite, Texas 75150

Deadline/Due Date: September 23, 2019  
2:00 p.m.

Please take note that the above referenced Request for Bid Construction is amended as follows.

**A. 19188-General Items, Specifications, Drawings (See Document Below)**

There are no further changes/additions at this time. If there are any questions concerning this request for bid construction, please contact the Purchasing Department at 972/860-7771.

**END OF ADDENDUM**

# Addendum Number 05

September 20, 2019

To Drawings and Specifications dated July 12, 2019

## DCCCD FAMILY/UNISEX RESTROOMS

Prepared by: PBK  
14001 Dallas Parkway, Suite 400  
Dallas, Texas 75240

PBK Project No.: 19188

### Notice to Proposers:

- A. Receipt of this Addendum shall be acknowledged on the Proposal Form.
- B. This Addendum forms part of the Contract documents for the above referenced project and shall be incorporated integrally therewith.
- C. Each proposer shall make necessary adjustments and submit his proposal with full knowledge of all modifications, clarifications, and supplemental data included therein. Where provisions of the following supplemental data differ from those of the original Contract Documents, this Addendum shall govern.

### GENERAL ITEMS

### SPECIFICATIONS

### DRAWINGS

- Item No. 01: **Explain Page AD1.01, General Demolition note 21. Hydromulch?** This is in case of accidental damage of the exterior landscaping from debris removal or subcontractor equipment or team members.
- Item No. 02: Water Motor Gong requirement in specification 21 11 16 is not needed per Leaf Engineers correspondence.
- Item No. 03: Based on Scope of work Fire extinguisher and Fire Cabinet is not needed. Removal of F.E from drawing G0.02 was intentional.



**END OF ADDENDUM NO. 5**

Project No. 19188 – Addendum No. 05